BOREWELL
COMPLETION REPORT

(6)

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 775

Date : 15/06/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP
Byatarayanapura Subdivision

2. Well Location : Sapthagiri layout Near Kasturba hosp

3. Total Well Depth / Drilled in Ft. : 1305 feet.

4. Casing Erected in Ft. : 197 feet.

5. Water Struck at the Depth of : 1020 feet.

6. Total Yield (Measuring method "V" Norch : 2 inch / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear clay

8. At the Depth of : 1150 feet.

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

Manager / Proprietor

Scanned by TapScanner

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 774

Date : 11/06/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Byatarayanapura Sub Division

2. Well Location : Vinayakanagara Near Lake.

3. Total Well Depth / Drilled in Ft. : 1312.00 feet.

4. Casing Erected in Ft. : 177 feet.

5. Water Struck at the Depth of : 1000 feet.

6. Total Yield (Measuring method "V" Norch : 2 inch / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear clean.

8. At the Depth of : 1100 feet.

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP Bangalore-92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner

BOREWELL COMPLETION REPORT

(8)

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 773 Date : 9/06/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Byatarayanapura Sub Division

2. Well Location : Palanahalli Thota Akkanapalya

3. Total Well Depth / Drilled in Ft. : 1308 feet.

4. Casing Erected in Ft. : 197 feet.

5. Water Struck at the Depth of : 935 feet.

6. Total Yield (Measuring method "V" Norch : 2½ inch / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear.

8. At the Depth of : 1180 feet

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

Manager / Proprietor

Scanned by TapScanner

BOREWELL COMPLETION REPORT

(10)

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 771

Date : 5/06/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP. Byatarayanapura Sub Division

2. Well Location : Srinivasapura Near Saibaba Temple

3. Total Well Depth / Drilled in Ft. : 1308 feet.

4. Casing Erected in Ft. : 197 feet

5. Water Struck at the Depth of : 920 feet.

6. Total Yield (Measuring method "V" Norch : 3 inch / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear

8. At the Depth of : 1240 feet.

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

(9)

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 772

Date : 8/06/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Byatarayanapura Subdivision

2. Well Location : Srinivasapura Near Oxford School Near.

3. Total Well Depth / Drilled in Ft. : 1312 feet.

4. Casing Erected in Ft. : 217 feet.

5. Water Struck at the Depth of : 960 feet

6. Total Yield (Measuring method "V" Norch : Failur / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Failur

8. At the Depth of : Failur

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump —

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

(1)

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 780

Date : 17/08/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Byatarayanapura Sub division
2. Well Location : Chamundi Layout. I 8th main Kogilu
3. Total Well Depth / Drilled in Ft. : 1308 feet.
4. Casing Erected in Ft. : 177 feet.
5. Water Struck at the Depth of : 980 feet
6. Total Yield (Measuring method "V" Norch : 2 1/2 inch / Inches on "V" Norch)
7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear.
8. At the Depth of : 1070 feet.
9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP Bangalore - 92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

123

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs ARK. Byatarayanappa Bangalore. Dated 20.12.20 On His/Her Land Located at Chamundi layout 1st Main Kogilu. in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes.

★ The Area Investigated has a slope towards North to South.

★ Radius 90° to 240° from centre of the Point.

★ Approximate Casing pipe Required 200 to 260 feet.

★ No of Water Bearing Zones 3 nos.
700, 800 feet, 910 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 900 to 1100 feet. for Better Storage.

★ The Approximate Yield May be 2 to 2½ inch. GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore - 92

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

122

Gollarahatti, Magadi Main Road, Bangalore - 560091

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE Byatarayanapura Sub Division. Dated 20.02.22 On His/Her Land Located at Dwarkanagara 5th Main in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes. ✓

★ The Area Investigated has a slope towards West to North.

★ Radius 0 to 90° from centre of the Point.

★ Approximate Casing pipe Required 90 feet 150 feet.

★ No of Water Bearing Zones 3 Nos.
600 feet 700 feet. 800 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1000 to 1200 feet. for Better Storage.

★ The Approximate Yield May be 1½ inch to 2 inch GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

121

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE. Byatarayanapura Sub Division. Dated 2.12.22 On His/Her Land Located at Kuvempunagara Ummrak. Kathigenahalli in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes. ✓

★ The Area Investigated has a slope towards East to South.

★ Radius 180° to 240° from centre of the Point.

★ Approximate Casing pipe Required 160 to 240 feet.

★ No of Water Bearing Zones 3 Nos
700 feet. 800 feet. 960 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1000 to 1200 feet. for Better Storage.

★ The Approximate Yield May be 1½ inch to 2 inch GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BESCOM, Bangalore - 92

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

120

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs A.E.E. Byatarayanapura Sub Division. Dated 21.12.22 On His/Her Land Located at Maneshwara layout, Kadirenahalli. in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes. ✓

★ The Area Investigated has a slope towards North to East

★ Radius 90° to 180° from centre of the Point.

★ Approximate Casing pipe Required 160 feet to 240 feet.

★ No of Water Bearing Zones 3 NOS.
800 feet, 900 feet 1000 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1100 to 1300 feet. for Better Storage.

★ The Approximate Yield May be 2 inch to 3 inch GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

119

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs A.E.E. Byatarayanappa, Sub Division. Dated 2.12.2014 On His/Her Land Located at Someshwara layout Near Kattigenahalli. in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes ✓

★ The Area Investigated has a slope towards East to South.

★ Radius 180° to 240° from centre of the Point.

★ Approximate Casing pipe Required 150 to 200 feet.

★ No of Water Bearing Zones 3 Nos
200 feet, 900 feet, 1200 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1200 to 1400 feet. for Better Storage.

★ The Approximate Yield May be 1½ to 2 inch. GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

118

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE. Byatarayanapura Sub Division. Dated 8.01.2021 On His/Her Land Located at Sadhashivanagar Layout Near Parameshwara. In Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes, ✓

★ The Area Investigated has a slope towards North to East

★ Radius 90° to 180° from centre of the Point.

★ Approximate Casing pipe Required 160 feet to 230 feet.

★ No of Water Bearing Zones 3 nos

700 feet, 800 feet, 1000 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1000 to 1100 feet for Better Storage.

★ The Approximate Yield May be 1½ to 2 inches GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

117

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE-Byatarayanapura Sub Division. Dated 3.01.2024 On His/Her Land Located at Vinayakanagara near cave in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes, ✓

★ The Area Investigated has a slope towards East to South.

★ Radius 180° to 240° from centre of the Point.

★ Approximate Casing pipe Required 80 feet to 170 feet.

★ No of Water Bearing Zones 3 Nos
400 feet 500 feet 600 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 600 feet to 900 feet. for Better Storage.

★ The Approximate Yield May be 1½ inch to 2 inch GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091

116

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE. Byatarayanaiahgaru Dated. 8/01/20 On His/Her Land Located at Polanahalli Thota Near Pagalcalonie. in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes ✓

★ The Area Investigated has a slope towards East to South.

★ Radius 180° to 240° from centre of the Point.

★ Approximate Casing pipe Required 150 feet to 240 feet.

★ No of Water Bearing Zones 3 Nos.
500 feet, 600 feet, 800 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 800 feet to 1000 feet for Better Storage.

★ The Approximate Yield May be 2 inch to 3 inch GPH.





SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091 124

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE. BBMP. Byatarayanapura Sub Division. Dated 4.1.03.2021 On His/Her Land Located at Srinivasapura Near DR Ford School in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes ✓

★ The Area Investigated has a slope towards North to East.

★ Radius 90° to 180° from centre of the Point.

★ Approximate Casing pipe Required 30 feet to 170 feet.

★ No of Water Bearing Zones 3 nos.
800 feet, 900 feet 1200 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1200 feet to 1400 feet for Better Storage.

★ The Approximate Yield May be 1½ inch to 2 inch GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

Scanned by TapScanner

SAVE WATER
Save Life

Mob: 9731993115
9448004619

SOMESHWARA WATER DIVINING

INVESTIGATION OF UNDER GROUND WATER

Gollarahatti, Magadi Main Road, Bangalore - 560091 125

GROUND WATER SURVEY REPORT

The Investigation was Carried Out as Per Application / Request By Mr/Mrs AEE. BBMP. Bataraya pura Sub division. Dated 1/03/2021 On His/Her Land Located at Srinivasapura Near Saisaba Temple in Order to access the Ground Water Potential of the Area for Domestic ☐ Irrigation ☐ Industrial ☐ Purposes, ✓

★ The Area Investigated has a slope towards North to East

★ Radius 90° to 180° from centre of the Point.

★ Approximate Casing pipe Required 20 to 140 feet.

★ No of Water Bearing Zones 3 Nos

600 feet, 800 feet, 1100 feet.

★ From the above Observation, a Borewell is Recommended for Drilling upto 1200 feet to 1400 feet for Better Storage.

★ The Approximate Yield May be 2 to 3 inch. GPH.



SHIVA KUMAR
Researcher / Diviner

TERMS & CONDITIONS:

1. The information furnished in this report regarding the subsurface and quantity of water are predictions which may vary due to a natural phenomena such as non-homogeneous sub surface of the earth and indulating terrain and also due to limitations of the geo-physical instruments used for prospecting.
2. The point(s) marked are those with maximum yield. The water researcher cannot take any responsibility for reduced yield in case the point(s) is shifted.
3. Feasible spots marked as per customers request.
4. The report is valid for 60 days from the date of survey.

Asst. Executive Engineer
Project Division
Yelahanka Zone

Scanned by TapScanner

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

(2)

No. : 779 Date : 29/10/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Byatarayanapura Sub Division

2. Well Location : Dwarkanagara 5th main

3. Total Well Depth / Drilled in Ft. : 1312 feet.

4. Casing Erected in Ft. : 217 feet.

5. Water Struck at the Depth of : 1050 feet.

6. Total Yield (Measuring method "V" Norch : 1½ inches / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear

8. At the Depth of : 1120 feet.

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner

BOREWELL COMPLETION REPORT

(3)

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 778

Date : 14/10/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Bhatarayanapura Sub Division

2. Well Location : Kuvempumagara 4th cross.

3. Total Well Depth / Drilled in Ft. : 1308 feet.

4. Casing Erected in Ft. : 197 feet.

5. Water Struck at the Depth of : 1060 feet

6. Total Yield (Measuring method "V" Norch : 1½ inch / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear clear

8. At the Depth of : 1110 feet

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bengaluru - 92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner

BOREWELL
BOREWELL
COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9[illegible] / 9[illegible]

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 777

Date : 19/07/2021

1. Customer's Name and Address with Telephone No. : AEE EEMS
Bhadravathi Sub Station

2. Well Location : Munesharam layout Kathriguppe

3. Total Well Depth / Drilled in Ft. : 1312 feet

4. Casing Erected in Ft. : 217 feet

5. Water Struck at the Depth of : 1030 feet.

6. Total Yield (Measuring method "V" Notch : 2½ inch / Inches on "V" Notch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear.

8. At the Depth of : 1020 feet.

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

Asst. Executive Engineer
Project Division
Yelahanka Zone

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report. I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

Manager / Proprietor

Scanned by TapScanner

BOREWELL
COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 776

Date : 16/07/2021

1. Customer's Name and Address with Telephone No. : AEE. BBMP Byatarayanapura Sub Division

2. Well Location : Someshwara Layout

3. Total Well Depth / Drilled in Ft. : 1308 feet Kasturinagar

4. Casing Erected in Ft. : 177 feet.

5. Water Struck at the Depth of : 1070 feet.

6. Total Yield (Measuring method "V" Norch : 1½ inch / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear.

8. At the Depth of : 1080 feet

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP Bangalore-92

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

Party's Signature

~~Manager~~ / Proprietor

Scanned by TapScanner